

Approved Body No. 1121

Certificate of Constancy of Performance

1121-CPR-UK-ABB7573

In compliance with Construction Products Regulation 2011 (retained EU law EUR 2011/305) as amended by the Construction Products (Amendment etc.) (EU Exit) Regulations 2019 and the Construction Products (Amendment etc.) (EU Exit) Regulations 2020, this certificate applies to the Construction Product:

“BRITON 372 (See ANNEX A) 389 (See ANNEX B) 1438 (See ANNEX C) Push Pad Range” Emergency Exit Devices

Intended use:- For use on single and double leaf escape route doors, including fire resisting control doors.

Essential characteristics	Performance	Designated Standard
Mechanical Test Evidence : 145924 / 145925 / 172273 / 178803 / 178803 / 178821 / 180257 / 180622 / 181094 / 182650/C/F/H/I&K / 196439 / WIL 427612 / WIL 438045 & WIL 518140 Fire Test Evidence : WF 332444 / WF 393476 / WF 417359 / WF 417361 / WF417363 & WF 422916 Iss 2		
Clause 4.2.1 Ability to release (for doors on escape routes) Release function Push pad Single doorset Double doorset Exposed edges and corners Push pad installation Operating element projection Operating element face (Push Pad) Push pad operating gap Test rod Push pad release operation Accessible gap Door free movement Top vertical bolt Covers for vertical rods Keepers Keepers dimensions Door mass and dimensions Outside access device Release forces Security requirement	< 1 sec Pass Pass Pass Pass Z < 250 mm W < 100mm Pass Pass Pass Pass Pass Pass Pass Pass Pass Pass – (372 Annex A Only) NPD Pass Pass – (372 Annex A Only) Door mass ≤ 200 Kg, door height ≤ 2500 mm, door width ≤ 1300 mm Pass Type B < 150 N Grade 4	BS EN 179:2008
Clause 4.2.1 Durability of ability to release against aging and degradation (for doors on escape routes) Corrosion resistance Temperature range Covers for vertical rods Lubrication Re-engagement force Durability Abuse resistance – Push Pad Abuse resistance – Vertical rod Final examination	Grade 3 : 96 hours Operating forces at -10 C° and + 60 C° < 50% in excess of the operating forces at +20 C° NPD Lubrication every 20 000 cycles < 50 N Grade 7: 200 000 cycles 500 N & 1000N 500 N – (372 Annex A Only) Type B < 150 N	

Approved Body No. 1121

Certificate of Constancy of Performance

1121-CPR-UK-ABB7573

In compliance with Construction Products Regulation 2011 (retained EU law EUR 2011/305) as amended by the Construction Products (Amendment etc.) (EU Exit) Regulations 2019 and the Construction Products (Amendment etc.) (EU Exit) Regulations 2020, this certificate applies to the Construction Product:

Essential characteristics	Performance	Designated Standard
Clause 4.2.1 Self closing ability C (for fire/smoke doors on escape routes) Re-engagement force	< 50 N	BS EN 179 : 2008
Clause 4.2.1 Durability of self closing ability C against aging and degradation (for fire/smoke doors on escape routes) Durability Re-engagement force	Grade 7: 200 000 cycles < 50 N	
Clause 4.2.1 Resistance to fire E (integrity) and I (insulation) (for fire doors on escape routes) Suitability of panic exit devices for use on fire resisting doorsets assemblies – Additional requirements	Grade B : Suitable for use on fire door assemblies.	
Clause 4.1.25 Control of Dangerous substances	If a reference to dangerous substances is added in the table ZA.1, the following claim is suggested: Pass: the materials in the device do not contain or release any dangerous substances in excess of the maximum levels specified in existing European material standards or any national regulations.	

Approved body No. 1121

Certificate of Constancy of Performance

1121-CPR-UK-ABB7573

In compliance with Construction Products Regulation 2011 (retained EU law EUR 2011/305) as amended by the Construction Products (Amendment etc.) (EU Exit) Regulations 2019 and the Construction Products (Amendment etc.) (EU Exit) Regulations 2020, this certificate applies to the Construction Product:

Briton Product	Single Door (Standard Keeper)	Double Door (Standard Keepers)	Approved with Alternate Strike or Keeper			
			378 DDS	376 MDS	378 MDS	379 MDS
ANNEX A						
372	√	√	-----	√	-----	-----
372M	√	√	-----	√	-----	-----
372OEM	√	√	-----	√	-----	-----
372.P	√	√	-----	√	-----	-----
372M.P	√	√	-----	√	-----	-----
372OEM.P	√	√	-----	√	-----	-----
ANNEX B						
389.N	√	√	-----	-----	-----	√
389M.N	√	√	-----	-----	-----	√
389OEM.N	√	√	-----	-----	-----	√
ANNEX C						
1438	√	√	√	-----	√	-----
1438M	√	√	√	-----	√	-----
1438OEM	√	√	√	-----	√	-----
Accessories						
Model Number		Description				
Briton 1413.LE		Lever outside access device (Suitable for use with all devices)				
Briton 1413.KE		Knob outside access device (Suitable for use with all devices)				
Briton 1413.BP		Retrofit Plate (Suitable for use with all devices)				
Briton 9260 Codelock		Lever outside access device (Suitable for use with 372 & 1438 range only)				
Rim cylinders		For use with 1438 products only				

Approved body No. 1121

Certificate of Constancy of Performance

1121-CPR-UK-ABB7573

Placed on the market under the name of

**Allegion (UK) Ltd
35 Rocky Lane
Aston
Birmingham
West Midlands
B6 5RQ
United Kingdom**

and produced in the manufacturing plant

V/017

This is coded format and the information is held by the Approved Body

This certificate attests that all provisions concerning the assessment and verification of constancy of performance and the performances described in Annex ZA of the standard(s)

BS EN 179 : 2008

Under System 1 for the performance set out in this certificate are applied and that the Factory Production Control conducted by the manufacturer is assessed to ensure the constancy of performance of the construction product.

This certificate was first issued on **15/07/2021** and reissued on **13/05/2023** and will remain valid as long as neither the designated standard, the Construction Product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, or unless suspended or withdrawn by the Approved Product Certification Body.

UKCA certificate valid to: **12/05/2026**



0087



Paul Duggan
Certification Manager

**Warringtonfire Testing and Certification Limited
Suite 302, The Genesis Centre, Birchwood, Warrington, WA3 7BH, UK**