

Approved Body No. 1121

Certificate of Constancy of Performance

1121-CPR-UK-AE7613

In compliance with Construction Products Regulation 2011 (retained EU law EUR 2011/305) as amended by the Construction Products (Amendment etc.) (EU Exit) Regulations 2019 and the Construction Products (Amendment etc.) (EU Exit) Regulations 2020, this certificate applies to the Construction Product:

(the Construction Products Regulation or CPR), this certificate applies to the construction product

Briton 2130B.TE.C, Briton 2130B.TE.L & Briton 2130B.TE.S Overhead door closer (Size 3 to 4)

**Intended use:- For use on fire rated single leaf and double leaf doors
STANDARD DOOR MOUNT PULL SIDE FIXING APPLICATION.**

Essential characteristics	Performance	Designated Standard
Test Mechanical Ref : 636PCT, 135129 & WIL 428092		
Fire Test Evidence : WF 141156 Iss 3 / 148518 WF 148519 / WF 417359 / WF 417360 Iss 3 & WF No 422918 Iss 2		
Ability to release 5.1.2 release from any angle 5.1.3 Not possible to inhibit the release 5.1.4 Supply voltage 5.1.5 External electrical connection 5.1.6 Inlet for external wiring 5.2.1 General 5.2.2 Electrical release requirements 5.2.4 Durability 5.2.5 Angle of hold open 5.2.6 Manual release 5.2.7 Continuous hold open 5.2.8 Overload performance 5.2.9 Delayed release 5.2.10 Electrical performance 5.1.11 Temperature Rise 5.1.12 Damage 5.1.13 Fire / smoke doors	Pass Pass Pass Pass Pass Pass Pass Pass Pass Pass Pass Pass Pass Pass Pass Pass Pass Pass Pass Pass Pass Grade 1	EN 1155:1997+A1:2002/AC:2006
Essential characteristics	Performance	Designated Standard
<u>Durability of Ability to release</u> 5.2.14.1 corrosion 5.2.14.2 corrosion	Grade 3 (96 hours) Pass	
<u>Dangerous Substances</u> <u>Annex ZA3</u>	If a reference to dangerous substances is added in the table ZA.1, the following claim is suggested: Pass: the materials in the product do not contain or release any dangerous substances in excess of the maximum levels specified in existing European material standards or any national regulations	EN 1155:1997+A1:2002/AC:2006

Notified body No. 1121

Certificate of Constancy of Performance

1121-CPR-UK-AE7613

produced for

**Allegion (UK) Ltd
35 Rocky Lane
Birmingham
West Midlands
B6 5RQ
United Kingdom**

and produced in the manufacturing plant.

V/017

This is coded format, and the information is held by the Notified Body

This certificate attests that all provisions concerning the assessment and verification of constancy of performance and the performances described in Annex ZA of the standard(s)

EN 1155:1997+A1:2002/AC:2006

Under System 1 for the performance set out in this certificate are applied and that the Factory Production Control conducted by the manufacturer is assessed to ensure the constancy of performance of the construction product.

This certificate was first issued on **29/10/2020** and reissued on **11/03/2023** and will remain valid as long as neither the designated standard, the Construction Product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, or unless suspended or withdrawn by the Approved Product Certification Body.

UKCA certificate valid to: **10/03/2026**



0087



Paul Duggan
Certification Manager

**Warringtonfire Testing and Certification Limited
Suite 302, The Genesis Centre, Birchwood, Warrington, WA3 7BH, UK**