warringtonfire Proud to be part of element

Approved Body No. 1121

Certificate of Constancy of Performance

1121-CPR-UK-AG7646

In compliance with Construction Products Regulation 2011 (retained EU law EUR 2011/305) as amended by the Construction Products (Amendment etc.) (EU Exit) Regulations 2019 and the Construction Products (Amendment etc.) (EU Exit) Regulations 2020, this certificate applies to the Construction Product:

Briton 5400 Series Roller Latch See Annex A

Essential characteristics	Performance	Designated standard	
Mechanical test evidence: WIL 414125 Fire test evidence: WF 417357 & WF 4229176 iss.3			
Self-closing 5.4.2 Closing force	Grade 8 = 200Kg door mass with 15N maximum closing force.		
5.1.2 Re-latching force of latch bolt	>2.5N		
Durability of self-closing 5.3.1 Durability of latch action	Grade C = 200,000 cycles with no side load on latch bolt.		
Ability to maintain the door in the closed position and not contribute to its spread of fire	Grade 1: suitable for use on fire/smoke resistant door assemblies	EN 12209:2003 / AC:2005	
Dangerous substances	Pass: the materials in the lock do not contain or release any dangerous substances in excess of the maximum levels specified in existing European material standards or any national regulations (1)		

Intended use: For use on fire/smoke compartmentation doors

EWC-QU-FT-480 (Issue 7)

Page 1 of 3

warringtonfire Proud to be part of element

Approved Body No. 1121

Certificate of Constancy of Performance

1121-CPR-UK-AG7646

Placed on the market under the name of

Allegion (UK) Ltd 35 Rocky Lane Aston Birmingham B6 5RQ United Kingdom

and produced in the manufacturing plant

J/380

This is coded format, and the information is held by the Approved Body

This certificate attests that all provisions concerning the assessment and verification of constancy of performance and the performances described in Annex ZA of the standard(s)

EN 12209:2003 / AC:2005

Under System 1 for the performance set out in this certificate are applied and that the Factory Production Control conducted by the manufacturer is assessed to ensure the constancy of performance of the construction product.

This certificate was first issued on **15/07/2021** and reissued on **30/08/2023** and will remain valid as long as neither the designated standard, the Construction Product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, or unless suspended or withdrawn by the Approved Product Certification Body.

UKCA certificate valid to: 29/08/2026

al bagg-

Paul Duggan

Certification Manager



0087

Warringtonfire Testing and Certification Limited Suite 302, The Genesis Centre, Birchwood, Warrington, WA3 7BH, UK

EWC-QU-FT-480 (Issue 7)

Page 2 of 3



Approved Body No. 1121

Certificate of Constancy of Performance

1121-CPR-UK-AG7646

Annex A

Model No.	Description	Backset
Briton 5470.60	Roller Latch	60mm
Briton 5470.55	Roller Latch	55mm

EWC-QU-FT-480 (Issue 7)

Page 3 of 3