

Notified Body No. 2812

## **Certificate of Constancy of Performance**

## 2812-CPR-AE0012

In compliance with *Regulation 305/2011/EU* of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product:

### Briton 9965 Electrically powered hold open & Free swing door closer (Size 5)

Intended use: For use on fire single leaf and double leaf doors

STANDARD DOOR MOUNT PULL, TRANSOM MOUNT PUSH & PARALLEL ARM FIXING APPLICATIONS.

STANDARD DOOR MOUNT PULL, TRANSOM MOUNT PUSH & PARALLEL ARM FIXING APPLICATIONS.		
Essential characteristics	Performance	Harmonised technical
		specification
	141203/P / 141718 / 141718/F / 14385	
Fire Test Ref's : WF 140181 / WF 148518 / WF 148519 / WF 417359 / WF 417360 lss 3 & WF 422918 lss 2		
Ability to release		
5.1.2 release from any angle	Pass	
5.1.3 Not possible to inhibit the release	Pass	
5.1.4 Supply voltage	Pass	
5.1.5 External electrical connection	Pass	
5.1.6 Inlet for external wiring	Pass	
5.2.1 General	Pass	
5.2.2 Electrical release	Pass	
requirements		
5.2.4 Durability	Pass	EN1155:1997+A1:2002/AC:2006
5.2.5 Angle of hold open	Pass	
5.2.6 Manual release	Pass	
5.2.7 Continuous hold open	Pass	
5.2.8 Overload performance	Pass	
5.2.9 Delayed release	NPD	
5.2.10 Electrical performance	Pass	
5.2.11 Temperature Rise	Pass	
5.2.12 Damage	Pass	
5.2.13 Fire / smoke doors	Grade 1	
Essential characteristics	Performance	Harmonised technical
		specification
Durability of Ability to release		
5.2.14.1 corrosion	Grade 3 (96 hours)	
5.2.14.2 corrosion	Pass	
Dangerous Substances	If a reference to dangerous	
Annex ZA3	substances is added in the table	EN1155:1997+A1:2002/AC:2006
	ZA.1, the following claim is	
	suggested:	
	Pass: the materials in the hinge do	
	not contain or release any dangerous	
	substances in excess of the	
	maximum levels specified in existing	
	European material standards or any	
	national regulations	





# **Certificate of Constancy of Performance**

## 2812-CPR-AE0012

Placed on the Market under the Name of

Allegion (UK) Ltd 35 Rocky Lane Birmingham West Midlands B6 5RQ United Kingdom

and produced in the manufacturing plant

#### V/017

#### This is coded format and the information is held by the Notified Body

This certificate attests that all provisions concerning the assessment and verification of constancy of performance and the performances described in Annex ZA of the standard(s)

# EN 1155:1997+A1:2002/AC:2006

Under System 1 for the performance set out in this certificate are applied and that the Factory Production Control conducted by the manufacturer is assessed to ensure the constancy of performance of the construction product.

This certificate was first issued on **29/10/2020** and re-issued on **29/03/2023** and will remain valid as long as neither the harmonised standard, the Construction Product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, or unless suspended or withdrawn by the Notified Product Certification Body.

CE Marking certificate valid to: 28/03/2026

ERO Project Reference: ERO 034621 P1746

Paul Duggan Certification Manager



CSF408-NL 7.0