

Notified Body No. 2812

Certificate of Constancy of Performance

2812-CPR-AE5012

In compliance with *Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011* (the Construction Products Regulation or CPR), this certificate applies to the construction product:

Briton 3934 Electrically powered hold open & freeswing Door Closer (Size 3 to 4)

**Intended use: For use on fire single leaf and double leaf doors
STANDARD DOOR MOUNT PULL SIDE & TRANSOM MOUNT PUSH SIDE APPLICATION**

| Essential Characteristics | Performance | Harmonised Technical Specification |
|---|--|------------------------------------|
| <p>Mechanical Test Evidence: 141262 / 141262/F / 141262/FP / 141262/P / WIL 327386 / WIL 506536 & WIL 521855</p> <p>Fire Test Evidence: WF 138941 Iss 5 / WF 313740</p> | | |
| Ability to release 5.1.2 release from any angle 5.1.3 Not possible to inhibit the release 5.1.4 Supply voltage 5.1.5 External electrical connection 5.1.6 Inlet for external wiring 5.2.1 General 5.2.2 Electrical release requirements 5.2.3 Door closing device requirements 5.2.4 Durability 5.2.5 Angle of hold open 5.2.6 Manual release 5.2.7 Continuous hold open 5.2.8 Overload performance 5.2.9 Delayed release 5.2.10 Electrical performance 5.2.11 Temperature Rise 5.2.12 Damage 5.2.13 Fire / smoke doors | Pass Pass 24V Pass Pass Pass Pass Pass Pass Pass > 65° Pass Pass NPD NPD Pass Pass Pass Grade 1 | EN1155:1997+A1:2002/AC:2006 |
| Durability of Ability to release 5.2.4 Durability 5.2.14.1 corrosion 5.2.14.2 corrosion | 50,000 Test Cycles Grade 3 (96 hours) Pass | EN1155:1997+A1:2002/AC:2006 |
| Dangerous Substances Annex ZA3 | Pass: the materials in the device do not contain or release any dangerous substances in excess of the maximum levels specified in existing European material standards or any national regulations | EN1155:1997+A1:2002/AC:2006 |

Notified Body No. 2812

Certificate of Constancy of Performance

2812-CPR-AE5012

In compliance with *Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011* (the Construction Products Regulation or CPR), this certificate applies to the construction product:

Briton 3934 Electrically powered hold open & freeswing Door Closer (Size 3)

**Intended use: For use on fire single leaf and double leaf doors
PARALLEL ARM APPLICATION**

| Essential Characteristics | Performance | Harmonised Technical Specification | |
|---|--|------------------------------------|--|
| Ability to release | | | |
| 5.1.2 release from any angle | Pass | | |
| 5.1.3 Not possible to inhibit the release | Pass | | |
| 5.1.4 Supply voltage | 24V | | |
| 5.1.5 External electrical connection | Pass | | |
| 5.1.6 Inlet for external wiring | Pass | | |
| 5.2.1 General | Pass | | |
| 5.2.2 Electrical release requirements | Pass | | |
| 5.2.3 Door closing device requirements | Pass | | |
| 5.2.4 Durability | Pass | EN1155:1997+A1:2002/AC:2006 | |
| 5.2.5 Angle of hold open | Pass > 65° | | |
| 5.2.6 Manual release | Pass | | |
| 5.2.7 Continuous hold open | Pass | | |
| 5.2.8 Overload performance | NPD | | |
| 5.2.9 Delayed release | NPD | | |
| 5.2.10 Electrical performance | Pass | | |
| 5.2.11 Temperature Rise | Pass | | |
| 5.2.12 Damage | Pass | | |
| 5.2.13 Fire / smoke doors | Grade 1 | | |
| Durability of Ability to release | | | |
| 5.2.4 Durability | 50,000 Test Cycles | | |
| 5.2.14.1 corrosion | Grade 3 (96 hours) | | |
| 5.2.14.2 corrosion | Pass | | |
| Dangerous Substances Annex ZA3 | Pass: the materials in the device do not contain or release any dangerous substances in excess of the maximum levels specified in existing European material standards or any national regulations | EN1155:1997+A1:2002/AC:2006 | |

Notified Body No. 2812

Certificate of Constancy of Performance

2812-CPR-AE5012

Placed on the Market under the Name of

Allegion (UK) Limited
35 Rocky Lane
Aston
Birmingham
B6 5RQ
United Kingdom

and produced in the manufacturing plant

CUZ31071-3

This is coded format and the information is held by the Notified Body

This certificate attests that all provisions concerning the assessment and verification of constancy of performance and the performances described in Annex ZA of the standard(s)

EN 1155:1997+A1:2002/AC:2006

Under System 1 for the performance set out in this certificate are applied and that the Factory Production Control conducted by the manufacturer is assessed to ensure the constancy of performance of the construction product.

This certificate was first issued on **30/10/2020** and re-issued on **16/02/2024** and will remain valid as long as neither the designated standard, the Construction Product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, or unless suspended or withdrawn by the Notified Product Certification Body.

CE Marking certificate valid to: **19/02/2026**

ERO Project Reference: **034621 P2256**



Pascal Coget
General Manager European Certification

CSF408-NL 8.0