

Notified Body No. 2812

## Certificate of Constancy of Performance 2812-CPR-AG0018

In compliance with *Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011* (the Construction Products Regulation or CPR), this certificate applies to the construction product

### Briton 5400 & AXA 7000 Series Locks See Annex A

**Intended use: For use on fire/smoke compartmentation doors**

Essential characteristics	Performance	Harmonised technical specification
Mechanical test evidence: WIL 414122, WIL 414123 & WIL 414786 Fire test evidence: WF 417357		
Self-closing 5.4.2 Closing force	Grade 8 = 200Kg door mass with 15N maximum closing force.	EN 12209:2003 / AC:2005
5.1.2 Re-latching force of latch bolt	>2.5N	
Durability of self-closing 5.3.1 Durability of latch action	Grade X = 200,000 cycles with 120N side load on latch bolt.	
Ability to maintain the door in the closed position and not contribute to its spread of fire	Grade 1: suitable for use on fire/smoke resistant door assemblies	
Dangerous substances	Pass: the materials in the lock do not contain or release any dangerous substances in excess of the maximum levels specified in existing European material standards or any national regulations (1)	

## Certificate of Constancy of Performance

**2812-CPR-AG0018**

Placed on the market under the name of:

**Allegion (UK) Ltd  
35 Rocky Lane  
Aston  
Birmingham  
B6 5RQ  
United Kingdom**

and produced in the manufacturing plant

**J/311**

**This is coded format and the information is held by the Notified Body**

This certificate attests that all provisions concerning the assessment and verification of constancy of performance and the performances described in Annex ZA of the standard:

**EN 12209:2003 / AC:2005**

Under System 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the constancy of performance of the construction product.

This certificate was first issued on **30/10/2020** and reissued on **20/12/2022** and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, or unless suspended or withdrawn by the Notified Product Certification Body.

CE Marking certificate valid to: **19/12/2025**

ERO Project Reference: **ERO 034621 P1748**



Paul Duggan  
Certification Manager

## Certificate of Constancy of Performance

**2812-CPR-AG0018**

**Annex A**

Model No.		Description	Backset
Briton 5420.60	AXA 7045	Mortice Sashlock	60mm
Briton 5430.60	AXA 7065	Bathroom Lock	60mm
Briton 5440.60	AXA 7055	Mortice Latch	60mm
Briton 5420.55		Mortice Sashlock	55mm
Briton 5430.55		Bathroom Lock	55mm
Briton 5440.55		Mortice Latch	55mm