

4 things to check

For Fire Door Closers

• **Fire Door.**
safety first!



1 Certification

It is recommended that a minimum **power size 3** door closer is used on a fire door and the closer is **UKCA, CE marked and fire rated**.

Remove the cover or slide the trimplate to check for the UKCA and CE logos and EN 1154 classification code marking.

Make sure the closer has been tested and UKCA & CE marked in the position it is fitted (ALWAYS refer to manufacturer instructions).



2 Operation

Release the door from the fully open position and ensure the door closes correctly into the frame.



3 Latching

Open the door to 5 degrees or 75mm (3 inches). Check that the closer **shuts the door onto the latch**.

If necessary:
- check closing and latching speeds are correctly set.



4 Maintenance

Door closers should be checked weekly and adjustments made where necessary.

Still in doubt?

Or in need of replacement hardware?

**Call us on
0330 8080 617**

Simple checks that could save lives!